

SMUD BOARD POLICY

Category: Strategic Direction	Title: RELIABILITY
	Policy Number: SD-4
Date of Adoption: August 21, 2003	Resolution No. 03-08-10
Revision 1: October 16, 2003	Resolution No. 03-10-14
Revision 2: May 6, 2004	Resolution No. 04-05-07
Revision 3: September 2, 2004	Resolution No. 04-09-08

Meeting customer energy requirements is a core value of the District.

Therefore:

- a) The District will assure all customer energy requirements are met. This will be accomplished through the use of: (i) its generation resources and purchase power portfolio 100 percent of the time; and (ii) its transmission assets to assure an overall availability of at least 99 percent.
- b) The District will achieve distribution system reliability by limiting the average frequency of outages to 1.16 or less per customer per year and by limiting the average duration of outages to less than 80.4 minutes per customer per year with no individual circuits exceeding these targets for more than two consecutive years.
- c) The District will maintain the electric system in good repair.

Monitoring Method: GM Report
Frequency: Semi-Annual

