

The PV/storage installation would be compliant with Title 24, JA11. The metering would comply with JA11.5.1 Remote Monitoring Capability and have a read tolerance of $\pm 0.5\%$ and provide real-time data pursuant to JA11.5.1(f). The renewable energy credits would be based on the JA11.5.1 metering that meets WREGIS metering requirements. The SMUD meter would be billing and crediting for only the energy (null power).